



LIFE SAFETY CRITERIA

NFPA 13 throughout (assumed)
2-hr shafts typ · 1-hr corridors
ST1 @ CORE · ST2 @ Hall 2 S
Elevator for accessible egress aid
Common path / travel: AOR Ch.10
Alarm/notification per IFC
Standpipe class I or II as req'd
Exit signs & emergency lighting
Fire extinguishers per IFC
See FP1.0 for riser schematic

CD DRAFT for bidding & AOR/PE completion. Geometry & TAKEOFF-4 quantities locked. Member sizes, sealed calcs, shop drawings by licensed professionals.

MIRAGE @ MANHATTAN	
1705 Manhattan Blvd · Harvey LA 70058 · Jefferson Parish	
LIFE SAFETY / EGRESS DIAGRAM	
SHEET G0.3	
SCALE: 3/32"=1'-0"	
CD-DRAFT-2 · FULL BUILD-OUT · JUL 15, 2026	
OWNER-GC CD DRAFT · NOT SEALED	AOR/PE SEAL (blank — Louisiana license)